SGIP Sarlu
Société Générale d'Innovation et de prestation

Import-Export, Fourniture, Énergie, BTP, Formation etc.

Conakry, 20 /09 /2026

CERTIFICATE OF WORK COMPLETION

Client	Société Minière de Dinguiraye (SMD) S.A. – Lefa
Site	Powerhouse and Kankarta feeder – SMD Léro mine site
Project	Transfer of Kankarta Feeder from 22 kV to 6.6 kV
Contract / Addendum	Contract PCON-0880-2024-000160 – Addendum No. AA-004 (PCON-0880-2024-000160-AA-004) – Ref. SMD-SOGEIP-07-2024
Contract period	From September 4, 2026 to September 18, 2026 (14 days)
Service Provider	SGIP SARLU – Société Générale d'Innovation et de Prestation

I, the undersigned, **Mr Adama FOFANA**, General Manager of **SGIP SARLU**, a company headquartered in Nongo, Commune de Lambanyi, Conakry (Republic of Guinea),

hereby certify on my honour that SGIP SARLU has carried out and fully completed the works for the transfer of the Kankarta feeder from the 22 kV supply to the 6.6 kV switch at the powerhouse, as provided for in the above-mentioned Addendum and in accordance with the Scope of Work (Annex 2) and the Bill of Quantities (Annex 3), namely:

- Site inspection and preparation of the work area, with the assistance of I&E
- Application of all safety procedures and isolation of the electrical system before starting work
- Installation of new poles along the planned route, from the powerhouse to the first Kankarta pole
- Installation of crossarms, insulators and other line hardware
- Pulling and installation of the new 6.6 kV overhead line
- Connection of the new line to the 6.6 kV switch at the powerhouse and to the existing Kankarta feeder
- Installation of high-voltage fuses and completion of all required electrical connections
- Inspection of all connections, testing, safe energization and commissioning

These works were carried out at the SMD Léro site (Lefa) in accordance with good engineering practice, electrical safety standards and the Company's HSE requirements. The new line has been handed over to the Plant Maintenance Department for normal operation.

I am aware that any false statement on my part will expose me to penalties in accordance with the rules in force. This certificate is issued for all legal and administrative purposes.

For SGIP SARLU

General Manager

Adama FOFANA

For Société Minière de Dinguiraye

Validation – Plant Maintenance Department

Name : Komah Mory

Date : 5/10/2026

Signature :

Société Minière de Dinguiraye
SMD
Superintendent Electricité et Instrumentation
Rép. de Guinée